CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION OFFICE OF THE STATE FIRE MARSHAL

FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7165-0028:143 Page 1 of 1

CATEGORY: Control Units (Non High-Rise)

LISTEE: Notifier, A Pittway Company, One Fire-Lite Place, Northford CT 06472-1653

Contact: Larry Flood (203) 484-1200

DESIGN: Model SGL-2000. Power-limited; manual or automatic; local or remote station (protected

premises). Refer to listee's data sheet for detailed product description and operational

considerations.

OPTIONS: Refer to listee's data sheet for required/optional accessories. When required, accessories

shall be CSFM listed.

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and

ordinances and in a manner acceptable to the authority having jurisdiction.

MARKING: Listee's name, model/catalog number and UL label.

APPROVAL: Listed as a fire alarm control unit for use with separately listed initiating and indicating

devices.

This control unit does not generate a temporal pattern signal. If the distinctive threepulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) in accordance with NFPA 72, 1993 Edition is required, the control unit must be used with appliances that can generate the temporal pattern signal. Refer to manufacturer's Installation

Manual for details.

XLF: 7165-0075:120



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: MAY 7, 2002 Listing Expires June 30, 2003

Authorized By: **DIANE K. AREND**, Senior Deputy

Program Manager